



LOURDES A. LEON GUERRERO
GOVERNOR (MAGA'HAGA)

JOSHUA F. TENORIO
LIEUTENANT GOVERNOR
(SIGUNDO MAGA'HAGA)

DEPARTMENT OF ADMINISTRATION

GENERAL SERVICES AGENCY

AHENSAN SETBISION HINIRAT
148 ROUTE 1 SOUTH MARINE CORPS DRIVE, PITI, GU 96915
TELEPHONE: (671) 475-1707/1708
FAX: (671) 472-4217/1727

EMAIL: GSAPROUREMENT@GSADOA.GUAM.GOV
WEBSITE: WWW.GSA.DOA.GUAM.GOV



EDWARD M. BIRN
DIRECTOR (DIREKTOT)

BERNADINE C. GINES
DEPUTY DIRECTOR
(SIGUNDO DIREKTOT)

March 17, 2022

Invitation For Bid
GSA-018-22

Installation of Existing Generator(s) 1ea. Kohler 83KW and 1ea. Kohler 24KW

Questions received from Advance Electrical Service Co. Guam on March 4, 2022

Question 1:

We'd like to ask for the make and models of the 83kw and 24kw generators.

Response:

24kw Kohler Power Generation Set Model: 20REOZK

83kw Kohler Power Generation Set Model: 80REOZJF

Questions received from JRN Air Conditioning & Refrigeration March 9, 2022

Question 1:

Please advise if Master Electrician is required for the project since under the Specifications, it states that, "upgrade of wires to main circuit breaker" is needed.

Response:

Yes, generator is upgraded to a higher kw therefore, a master electrician is needed for this project.

Question 2:

May we request plans/drawing and specification for (electrical/cable wire size, concrete base pad and chain-link fence)?

Response:

It is the contractor's responsibility to prepare as noted on scope of work.

Question 3

Under Specifications, the contractor will perform the start-up and commissioning, will the brochures/manual of the equipment be provided? In regards to the warranty of the equipment, would it still be covered by the supplier?

Response:

Yes, the manual will be provided. No. Warranty is not covered by the supplier.

Question 4:

Please advise if the contractor is in charge with the disposal of the old generator set.

Response:

No, contractor is responsible for disconnecting old unit; Department of Corrections will dispose.

Question 5:

Does the contractor need to apply for electrical permit at Department of Public Works for this project?

Response:

Yes, contractor is responsible for any permits needed to complete installation.


CLAUDIA S. ACFALLE
Chief Procurement Officer

Please Print
Acknowledgement Copy (Re-Fax to GSA)

Received By _____

Date: _____

Company Name: _____

Fax to: 475-1727 or 472-4217

Email to: gsaprocurement@gsadoa.guam.gov